



- 1.Design conforms to AS2638.2 .
- 2.Face to Face according to AS2638.2.
- 3.Flanges standard AS4087 PN16.
- 4.Pressure test according to AS2638.2.

DN	L	D	D1	D2	b	n-d	f	H	W
50	178	150	114	90	18	4-18	3	300	180
65	190	165	127	103	18	4-18	3	310	180
80	203	185	146	122	18	4-18	3	320	200
100	229	215	178	154	20	4-18	3	345	200
150	267	280	235	211	23	8-18	3	440	250
200	292	335	292	268	23	8-18	3	545	280
225	305	370	324	300	24	8-18	3	590	280
250	330	405	356	328	24	8-22	3	635	320
300	356	455	406	378	30	12-22	4	725	360
350	381	525	470	438	33	12-26	4	820	450
375	381	550	495	463	33	12-26	4	910	450
400	406	580	521	489	33	12-26	4	1000	600
450	432	640	584	552	33	12-26	4	1075	600
500	457	705	641	609	35	16-26	4	1150	730
600	508	825	756	720	42	16-30	5	1350	730

15	Top Nut	SS316		
14	Cap	AS 1831 500-7		
13	Dust Guard	EPDM		
12	O-Ring	EPDM		
11	O-Ring	EPDM		
10	Bushing Nut	Brass		
9	Washer	Nylon		
8	Up sealing	EPDM		
7	Bonnet	AS 1831 500-7		
6	Bolt	SS316		
5	Bonnet Gasket	EPDM		
4	Stem Nut	Brass		
3	Stem	SS410		
2	Wedge	AS 1831 500-7 +EPDM		
1	Body	AS 1831 500-7		
No.	Part	Material	Q'ty	Remarks
DRN	Wang	WEIGHT	MATERIAL	
CHK		SCALE	Gate Valve	
APP		DATE 12/07/2013		
hiwa			Z1711	
			REV	20131207

This document is the property of Huihua Valve Industry Co.
 Distribution of this document without the written consent of the owner is strictly forbidden
 Failure to comply will incur a liability for damages

<http://www.hiwa.cn> Website
 sales@hiwa.cn Email

86 - 533 - 6077200 Phone
 86 - 533 - 6077233 FAX

Huihua Valve Industry Co.
 No.36 MinAn Road New Hi-Tech Industry
 Zone Zibo Shandong China 255088 p.c